

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 731/UJS/DLWQTM/2025-26

Dated: 01/04/2025

It is certified that an inspection team headed by DR. VIKASH KANDARI, CHIEF CHEMIST

(Name of Officers with designation) from UTTARAKHAND JAL SANSTHAPHED

inspected the ST. ANN'S SENIOR SECONDARY SCHOOL, NEAR DOON HELIDROME, KULHAN, TARLA NAGAL, SHASTRADHARA ROAD, D.DUN

(Name & Address of the school) on 27/03/25 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 731/UJS/DLWQTM/25 dated 01/04/2025

of DISTRICT WATER TESTING LAB (PHED Lab) certified that the

ST. ANN'S SENIOR SECONDARY SCHOOL (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till FOR 06 MONTH

Technical Manager
DLWQTM
Uttarakhand Jal Sans
Dehradun

Signature with Seal: 

Name

Designation

Name & Address of the Office / Department UJS, D.DUN

To
ST. ANN'S SENIOR SECONDARY SCHOOL,
KULHAN, TARLA NAGAL, SHASTRADHARA, D.DUN
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



MANAGER
ST. ANN'S SR. SEC. SCHOOL
TARLA NAGAL, NEAR DOON HELIDROME
SHASTRADHARA P.



**District Level Water Quality Testing and Monitoring Laboratory
Uttarakhand Jal Sansthan, 32, Rajpur Road, Dehradun**



TC-13625

TEST REPORT

Name and Address of Organization/ Customer	St. Ann's Senior Secondary School, Near Doon Helidrome, Kulhan, Tarla nagal, Sahastradhara Road, Dehradun, Uttarakhand		
Test Report ID	731/UJS/DLWQTML/2025-26	Reporting Date	01/04/2025
ULR No.	TC1362524000000000134/F	Sample Location	Near Doon Helidrome, Kulhan, Tarla gal, Sahastradhara Road, Dehradun, Uttarakhand
Product Description	Drinking Water	Sample Collected by	Customer
Reference Sample Identification:	DLWQTML/UJS/2025-731		
Date of Start of Analysis:	27/03/2025		
Date of End of Analysis:	29/03/2025		
Date and Time of Sample Received:	27/03/25 & 03:00 PM		

SN	Parameters	Test Method	Result	Acceptable Limit As per (IS 10500:2012)	Permissible Limit (IS 10500:2012) in the Absence of alternative source
(A) Organoleptic and Physical Parameters					
1.	pH at 25°C	IS 3025 (Part 11) 2022	7.72	6.5 to 8.5	No Relaxation
2.	Total Dissolved Solids (TDS), at 180°C mg/L	IS 3025 (Part 16), 2023	66	500 Max	2000 Max
3.	Turbidity, NTU, Max	IS 3025 (Part 10), 2023	0.52	1 Max	5 Max
4.	Colour, Hazen	IS 3025 (Part 4): 2021	Less than 01	5 Max	15 Max
5.	Odour	IS 3025 (Part 5) : 2018	Agreable	Agreeable	Agreeable
(B) General Parameters Concerning Substances					
6.	Total Alkalinity (as CaCO ₃), mg/L	IS 3025 (Part 23), 2023	28	200 Max	600 Max
7.	Total Hardness (as CaCO ₃), mg/L	IS 3025 (Part 21), 2009	38	200 Max	600 Max
8.	Calcium as Ca, mg/l	IS 3025 (Part 40), 2019	4.8	75 Max	200 Max
9.	Chloride, mg/L	IS 3025 (Part 32), 2019	20	250 Max	1000 Max
10.	Magnesium as Mg, mg/l	APHA 24 th Ed -3500-Mg Method B:2023 (Calculation Method)	6.31	30 Max	100 Max

Note:-

1. The results listed refer only to tested sample and applicable parameters.
2. This certificate is not be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
3. The samples will be destroyed after Seven days from the date of issue of test certificate, unless otherwise agreed with customer.
4. The results apply to the sample as received
5. The Laboratory is responsible for all the information provided in the report, except when information is provided by the customer

**** End of Report****

[Signature]

MANAGER

Format No. UJS/MS/2025/01
ST. ANN'S SR. SEC. SCHOOL
TARLA NAGAL, NEAR DOON HELIDROME
SHASTRADHARA ROAD, D. DOON

Page 01 of 01

Review and Authorized By

[Signature]
[Signature]

(Dr. Vikash Kandari)

Technical Manager, Lab

**Technical Manager
DLWQTML**

**Uttarakhand Jal Sansthan
Dehradun**



District Level Water Quality Testing and Monitoring Laboratory
Uttarakhand Jal Sansthan, 32, Rajpur Road, Dehradun

TEST REPORT

Name and Address of Organization/ Customer	St. Ann's Senior Secondary School, Near Doon Helidrome, Kulhan, Tarla nagal, Sahastradhara Road, Dehradun, Uttarakhand		
Test Report ID	731A/UJS/DLWQTML/2025-26	Reporting Date	01/04/2025
		Sample Location	Near Doon Helidrome, Kulhan, Tarla gal, Sahastradhara Road, Dehradun, Uttarakhand
Product Description	Drinking Water	Sample Collected by	Customer
Reference Sample Identification:	DLWQTML/UJS/2025-731		
Date of Start of Analysis:	27/03/2025		
Date of End of Analysis:	29/03/2025		
Date and Time of Sample Received:	27/03/25 & 03:00 PM		

SN	Parameters	Test Method	Results	Acceptable Limit As per (IS 0500:2012)	Permissible Limit (IS 10500:2012) in the Absence of alternative source
(C) General Parameters Concerning Substances					
1	Fluoride, mg/L, Max	APHA 23rd Ed. 4500-F-D: 2023	0.12	1.0	1.5
2	Nitrate, mg/L, Max	APHA 23rd Ed. 4500-NO ₃ -B:2023	1.4	45	No Relaxation
3	Sulfate, mg/L, Max	APHA 23rd Ed. 4500-SO ₄ -E:2023	42	200	400
(D) Microbiological Parameters					
SN	Parameters	Test method	Results	Requirements as per IS 10500:2012	
4	Total Coliform (in 100ml)	IS 15185:2021	Absent	Shall not be detectable in any 100 ml sample	
5	E. coli, 100ml (in 100ml)	IS 15185:2021	Absent	Shall not be detectable in any 100 ml sample	

Note:-

1. The results listed refer only to tested sample and applicable parameters.
2. This certificate is not be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
3. The samples will be destroyed after Seven days from the date of issue of test certificate, unless otherwise agreed with customer.
4. The results apply to the sample as received
5. The Laboratory is responsible for all the information provided in the report, except when information is provided by the customer

**** End of Report****

MANAGER
ST. ANN'S SR. SEC. SCHOOL
TARLA NAGAL, NEAR DOON HELIDROME
SHASTRADHARA ROAD, DEHRADUN

Review and Authorized By

(Dr. Vikash Kandari)
Technical Manager, Lab
Technical Manager
DLWQTML
Uttarakhand Jal Sansthan
Dehradun